

TITLE 19, DIVISION 1, CHAPTER 1.5

Text of Modified Regulations

Changes are illustrated by double underline for additions to language originally proposed and by double strikeout for deletions to language originally proposed.

§ 208. Special Provisions. ~~Fire Alarm and Automatic Sprinkler Systems and Devices~~

(b) Portable Gasoline Containers.

(1) Portable gasoline containers shall be approved and listed by the State Fire Marshal pursuant to Health and Safety Code Section 13139(a). For the purpose of clarification, Health and Safety Code Section 13139(a) is repeated.

Health and Safety Code §13139(a) On or before January 1, 2008, the State Fire Marshal shall approve and list portable gasoline containers that are designed and constructed according to one of the following child-resistant standards:

(1) Construction and design standards which are substantially the same as the American Society for Testing and Materials (ASTM) F2517-05 standard, issued by ASTM International, or any successor standard issued by ASTM International.

(2) Construction and design standards approved by a national testing laboratory recognized by the State Fire Marshal.

(2) Prohibition of Sale. On or after April 1, 2008, the marketing, distribution, offering for sale, or selling of portable gasoline containers in this State is prohibited unless the containers were manufactured prior to April 1, 2008, or are approved and listed by the State Fire Marshal.

Exception: Retailers are permitted to sell existing supplies of portable gasoline containers that have not been approved and listed by the State Fire Marshal when the manufactured date is prior to January 1, 2008.